

2033106 Revitalize Steam Tunnels - Pre Bid RFI Tracker - Response 3

RFI #	RFI Question	RFI Answer	Image / Sketch / Reference Etc.
5	Please note that where the steam, condensate and chilled water piping enters each building, there is a tilde on the end of the line with no actual point-of-connection shown. Other than a standard en-of-main drip, the details don't appear to show any additional valves, specialties, etc. to be installed once the piping enters each building. Please confirm exactly where the ti-in point is to be made in each building and if there are to be any valves and/or specialties to be installed at these locations.	As noted, the points of connections are to be coordinated with the COTR and shall be made inside the building at the "existing" shutoff valves. There is no requirement for new valves or steam specialties except as otherwise noted or specified	
6	Please provide sizes and quantities of electrical piping to be demolished.	Due to possible hazardous material within the tunnel, a CCTV robot has surveyed it. The video shared in the second RFI response shows a representative sample of the abandoned electrical that will be removed.	
7	Provide quantities of lights to be demolished.	Due to hazardous material within the tunnel, the tunnel has been surveyed by a CCTV robot only. The extent of lights to be demolished is based on similar efforts for bidding, assume 14 fixtures similar to those being called for installation.	