

2433109 Redistribute Campus Wide Electrical Loads REQUEST FOR INFORMATION					
RFI #	Drawing/Spec Category	Question	Response	Date In	Date Out
1	C103 Note 10	Note 10 on C103 states to coordinate the utility excavation with the CRZ of the adjacent tree and replace with new tree if tree is impacted. The CRZ is not identified and the excavation extent can not be determined at this time. Please advise if all bidders should include cost for tree replacement, or if would be handled as a contract modification once the impact can be fully determined.	Utility excavation will be part of contractor means & methods. Please include cost of tree replacement.	9/8/2026	9/16/2026
2	C103 Note 7	Note 7 on c103 states to replace existing tall grass with short grass and to refer to division 1 specifications. No specifications could be found in division 01 that specifies the species for short or tall grass.	Note 7/C103 states to replace existing tall grass with short grass. This is in order to provide a better clearance zone around the new pad-mounted electrical equipment. While division 1, section 28 references sod replacement of damaged turf areas, the contractor shall initially plant annual and perennial rye in these locations followed by the intent of documents to have Contractor seed the permanent areas per C802/permanent seeding notes.	9/8/2026	9/16/2026
3	C103 Note 8	Note 8 on C103 states to replace existing tall grass plantings in kind. Please provide specification of existing tall grass.	Note 8/C103 states to replace tall grass plantings in-kind - according to existing documentation plantings are Panicum virgatum 'Shenandoah', Shenandoah Switchgrass.	9/8/2026	9/16/2026
4	C103 Note 11	Note 11 on C103 states to replace in kind plantings impacted by utility trenching. Please provide specification on existing plants, including species and size.	Note 11/C103 states to replace plantings and mulch in-kind - Impacted shrubs appear to be leatherleaf viburnum.	9/8/2026	9/16/2026
5	C103 Note 4	Note 4 on C103 indicates a new concrete channel (replace in kind). Please provide detail of existing channel.	See 2/C501 for typical pavement section and 4&4A/C501 for enlarged curb details.	9/8/2026	9/16/2026
6	Spec 010000.22.1	Specification Section 010000.22.1 requires the contractor to obtain and pay for all applicable permits. Please advise what permits are required, and if the contractor is to pay for the permit, please provide an allowance to carry.	Per Division 1 the Contractor shall pay the required fees and obtain the DOEE Sediment and Erosion Control Permit once approved and made available. See attached revised bid schedule which incorporates a \$3,000 allowance.	9/8/2026	9/16/2026